

Safe Work Procedure

Disposal and Transporting Flammable Liquids

Facility:	Written By:	Approved By:	Date Created	Date of Last Revision:

Hazards Present:	PPE or Devices Required:	Additional Training Required:
Potential fire Inhalation of chemicals / toxins Burns	Steel toed boots Eye protection Hand protection	Fire Extinguisher Training

Safe Work Procedure:
<p>1 Disposing areas shall be established with adequate ventilation, grounding, bonding, container vents, and drip cans in lieu of disposal at individual work stations whenever possible</p> <p>2 When disposing flammables from drums or bulk containers, drip cans, vents, grounding and bonding shall be used</p> <p>3 Gravity transfer may be utilized when small amounts of volatile liquids are required.</p> <p>4 Pumping shall be accomplished with a positive displacement pump</p> <p>5 Hydraulic transfer shall be used only when a control system is in place to prevent over pressurization of system</p>

If an emergency situation occurs while conducting this task, or there is an equipment malfunction, engage the emergency stop and follow the lock out procedure

REPORT ANY HAZARDOUS SITUATIONS TO YOUR SUPERVISOR

<p>Guidance Documents/Standards:</p> <p>MB Workplace Safety & Health Act & Regulations: 6 Personal Protective Equipment 19 Fire and Explosive Hazards 35 Workplace Hazardous Materials Information Systems Safe Work Bulletin #178</p>	<p>This Safe Work Procedure will be reviewed any time the task, equipment or materials change and at a minimum of every three years</p> <hr/> <p>Reviewed By Worker Rep/WSH Committee:</p> <p>Date:</p>
--	--