

Safe Work Procedure

Handling Propane

Facility:	Written By:	Approved By:	Date Created	Date of Last Revision:

Hazards Present:	PPE or Devices Required:	Additional Training Required:
Muscle strain Fire hazard Explosion Burns	Steel toed boots Eye protection Hand protection	Fire Extinguisher Training

Safe Work Procedure:
1 Ensure that tank valves and regulators are not removed before moving tank 2 Attach nylon sling in a "choker" fashion for loading, unloading, or moving tank 3 Make sure tank is stored at an upright position on level ground at proper temperature

If an emergency situation occurs while conducting this task, or there is an equipment malfunction, engage the emergency stop and follow the lock out procedure

REPORT ANY HAZARDOUS SITUATIONS TO YOUR SUPERVISOR

Guidance Documents/Standards: MB Workplace Safety & Health Act & Regulations: 6 Personal Protective Equipment 8 Musculoskeletal Injuries 19.10 Compressed Gas Equipment 35 Workplace Hazardous Materials Information Systems	This Safe Work Procedure will be reviewed any time the task, equipment or materials change and at a minimum of every three years Reviewed By Worker Rep/ WSH Committee: Date:
--	---